

## 认证说明

该证书只用于在网页浏览，证明赛尔特这个型号产品已获得认证。如需完整版

本，请用以下任意一种方式联系获得：

- 邮件：[sales@SETfuse.com](mailto:sales@SETfuse.com)。
- 客服。
- 销售人员。

感谢您对赛尔特的支持！



Product Service

# Attestation of Conformity

No. N8A 107221 0011 Rev. 01

**Model(s):** **LFR01-xxA10-yy, LFR01-xxxA10-yy, LFR01-450A08-yy**

**xx=50, 63, 80 and xxx=100, 125, 160, 200, 250, 315, 350, 400 denotes rated current 50A, 63A, 80A, 100A, 125A, 160A, 200A, 250A, 315A, 350A, 400A respectively.**

**yy=BB, FB, BT, FE denotes different terminal type**

**BB: Bolt blade terminal**

**FB: Flat bolt terminal**

**BT: Bolt tag terminal**

**FE: Flush end terminal**

**LFG35-xxxA02-BT**

**xxx=100, 125, 160, 200, 250, 315, 350, 400, 450, 500, 550, 600 denotes rated current 100A, 125A, 160A, 200A, 250A, 315A, 350A, 400A, 450A, 500A, 550A, 600A respectively.**

## Parameters:

Model:	LFR01-xxA10-yy, LFR01-xxxA10-yy	LFR01-450A08-yy	LFG35-xxxA02-BT
Rated voltage:	DC1000V	DC800V	DC250V
Rated current:	50A, 63A, 80A, 100A, 125A, 160A, 200A, 250A, 315A, 350A, 400A	450A	100A, 125A, 160A, 200A, 250A, 315A, 350A, 400A, 450A, 500A, 550A, 600A
Rated breaking capacity:	50kA		
Poles No.:	1-P		
Breaking range and utilization category:	aR		

**Tested according to:**

EN 60269-1:2007/A2:2014

EN 60269-4:2009/A2:2016

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.