

认证说明

该证书只用于在网页浏览，证明赛尔特这个型号产品已获得认证。如需完整版

本，请用以下任意一种方式联系获得：

- 邮件：sales@SETfuse.com。
- 客服。
- 销售人员。

感谢您对赛尔特的支持！

CERTIFICATE

No. B 107221 0014 Rev. 00

Model(s): LFR000-xxA10-yy,
LFR000-xxxA10-yy

xx=50, 63, 80 and xxx=100, 125, 150, 160, 200, 250
denotes rated current 50A, 63A, 80A, 100A, 125A,
150A, 160A, 200A, 250A respectively.

yy=BT, BK denotes different terminal type

BT: Bolt tag terminal

BK: Blade knife terminal

Brand Name: SET

Parameters:

Rated voltage:	DC1000V
Rated current:	50A, 63A, 80A, 100A, 125A, 150A, 160A, 200A, 250A
Rated breaking capacity:	50kA
Poles No.:	1-P
Breaking range and utilization category:	aBat

Tested according to: IEC 60269-7:2021
IEC 60269-1:2006
IEC 60269-1:2006/AMD1:2009
IEC 60269-1:2006/AMD2:2014